

E-Treat™ Water Conditioning System

INSTALLATION OVERVIEW



Primary Installation considerations

- Install unit where water enters your house.
- A five micron pre-filter is recommended to remove sediment if you have cloudy water or if small particles are in your water. (Pleated cartridge is recommended for more filter area.)
- Pre-treat for Iron, Hydrogen Sulfide and Manganese.
- Water should be free of oil and grease.
- Maximum flow is 12 GPM.
- Minimum pressure is 15 psi.
- Maximum pressure is 125 psi.
- Minimum operating temperature is 34F. (Do not install outside in freezing weather.)
- Maximum operating temperature is 120F.
- Water pH range is 6 - 9.
- Maximum water hardness is 25 grains per gallon. (Contact dealer if levels are higher.)
- By-pass valve is included so unit may be isolated from plumbing if necessary.

NOTE: When installing unit, the inlet is on the LEFT, facing the valve looking directly into the ports. (Directional labels are on the valve).



With E-Treat systems the only moving part is your water!